



**City of Milpitas
Building and Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 www.ci.milpitas.ca.gov

**FIRESTOPPING SYSTEM
REQUIREMENTS**

Policy:

BDP-BLG41

Effective Date:

6/9/17

Proposed by:

BYC

Last Reviewed/
Revised:

Revised by:

Approved By: Gary King
Acting Chief Building Official

- 1) Firestopping systems shall be listed approved assemblies from the **same manufacturer** throughout the entire project.
- 2) All firestopping systems details per approved listing shall be provided on Architectural drawings and shall be referenced on drawings where firestopping systems is required.